



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0J2222

Greene Central School

Project Name: Lead Water Testing

Dave Kendall
 40 South Canal Street
 Greene, NY 13778

Project / PO Number: N/A
 Received: 10/30/2020
 Reported: 11/18/2020

Analytical Testing Parameters

Client Sample ID:	Room 6 Sink #1 - Rt	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 6:21
Lab Sample ID:	J0J2222-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0053	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1739	LLW

Client Sample ID:	Room 6 Sink #2 - Lft	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 6:21
Lab Sample ID:	J0J2222-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1745	LLW

Client Sample ID:	Room 3	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 6:22
Lab Sample ID:	J0J2222-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0325	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1747	LLW

Client Sample ID:	Room 1	Collected By:	Customer
Sample Matrix:	Drinking Water	Collection Date:	10/28/2020 6:23
Lab Sample ID:	J0J2222-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0043	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1748	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Room 2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:25
Lab Sample ID: J0J2222-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1750	LLW

Client Sample ID: 5th Grade Staff BR	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:27
Lab Sample ID: J0J2222-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1752	LLW

Client Sample ID: Staff Breakroom	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:28
Lab Sample ID: J0J2222-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1758	LLW

Client Sample ID: 5th Grade Boy's BR Sink #1 - LF	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:29
Lab Sample ID: J0J2222-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1800	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: 5th Grade Boy's BR Sink #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:29
Lab Sample ID: J0J2222-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1802	LLW

Client Sample ID: 5th Grade Boy's BR Sink #3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:29
Lab Sample ID: J0J2222-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1804	LLW

Client Sample ID: Fountain 5th Grade Left	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:30
Lab Sample ID: J0J2222-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1805	LLW

Client Sample ID: Fountain 5th Grade Right	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:30
Lab Sample ID: J0J2222-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1809	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: 5th Grade Girl's BR Sink #1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:31
Lab Sample ID: J0J2222-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1811	LLW

Client Sample ID: 5th Grade Girl's BR Sink #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:31
Lab Sample ID: J0J2222-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1813	LLW

Client Sample ID: 5th Grade Girl's BR Sink #3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:31
Lab Sample ID: J0J2222-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1815	LLW

Client Sample ID: Room 10	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:32
Lab Sample ID: J0J2222-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0092	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1821	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Room 12	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:34
Lab Sample ID: J0J2222-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1823	LLW

Client Sample ID: Room 14	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:35
Lab Sample ID: J0J2222-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.0150 AL	0.0010	mg/L		11/04/20 1404	11/04/20 1824	LLW

Client Sample ID: Room 16	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:37
Lab Sample ID: J0J2222-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0179	0.0150 AL	0.0010	mg/L		11/06/20 1357	11/09/20 2018	LLW

Client Sample ID: Room 13	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:38
Lab Sample ID: J0J2222-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0252	0.0150 AL	0.0020	mg/L	D	11/06/20 1357	11/10/20 1251	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Room 11	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:39
Lab Sample ID: J0J2222-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1838	LLW

Client Sample ID: Room 9	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:41
Lab Sample ID: J0J2222-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1843	LLW

Client Sample ID: Room 7	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:42
Lab Sample ID: J0J2222-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1845	LLW

Client Sample ID: Girl's Locker Room Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:44
Lab Sample ID: J0J2222-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1847	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Girl's Coach's Office Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:45
Lab Sample ID: J0J2222-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1849	LLW

Client Sample ID: Main Office BR Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:46
Lab Sample ID: J0J2222-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1851	LLW

Client Sample ID: Nurse's Office Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:47
Lab Sample ID: J0J2222-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0551	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1857	LLW

Client Sample ID: Nurse's BR Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:48
Lab Sample ID: J0J2222-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1859	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Boy's Locker Room Slnk	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:49
Lab Sample ID: J0J2222-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1901	LLW

Client Sample ID: Boy's Coach's Office Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:50
Lab Sample ID: J0J2222-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1903	LLW

Client Sample ID: Kitchen Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:19
Lab Sample ID: J0J2222-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1905	LLW

Client Sample ID: Gym Foyer Fountain Left	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:21
Lab Sample ID: J0J2222-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0041	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1908	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Gym Foyer Fountain Right	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:21
Lab Sample ID: J0J2222-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0064	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1910	LLW

Client Sample ID: Gym Foyer Boy's BR Sink 1Left	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:23
Lab Sample ID: J0J2222-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1912	LLW

Client Sample ID: Gym Foyer BOy's Sink 2 Right	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:23
Lab Sample ID: J0J2222-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1914	LLW

Client Sample ID: Gym Foyer Girl's BR Sink 1 Left	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:25
Lab Sample ID: J0J2222-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1920	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Gym Foyer Girl"s BR Sink 2 Right	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:25
Lab Sample ID: J0J2222-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0250	0.0150 AL	0.0100	mg/L	D	11/06/20 1357	11/10/20 1243	LLW

Client Sample ID: Gym Fountain Right	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:27
Lab Sample ID: J0J2222-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1922	LLW

Client Sample ID: 4th Grade Staff BR	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:30
Lab Sample ID: J0J2222-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1924	LLW

Client Sample ID: Room 19	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:30
Lab Sample ID: J0J2222-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.0150 AL	0.0010	mg/L		11/04/20 1516	11/04/20 1926	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Room 21	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:33
Lab Sample ID: J0J2222-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 1937	LLW

Client Sample ID: Room 23	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:35
Lab Sample ID: J0J2222-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0158	0.0150 AL	0.0020	mg/L	D	11/04/20 1517	11/06/20 1047	LLW

Client Sample ID: Room 25	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:37
Lab Sample ID: J0J2222-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0701	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 1945	LLW

Client Sample ID: Room 27	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:38
Lab Sample ID: J0J2222-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 1947	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Room 24	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:40
Lab Sample ID: J0J2222-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0336	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 1949	LLW

Client Sample ID: Room 29	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:42
Lab Sample ID: J0J2222-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 1951	LLW

Client Sample ID: Room 31	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:43
Lab Sample ID: J0J2222-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0135	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 1957	LLW

Client Sample ID: Room 30	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:45
Lab Sample ID: J0J2222-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0101	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 1959	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Room 28	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:47
Lab Sample ID: J0J2222-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0070	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2001	LLW

Client Sample ID: Room 22	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:49
Lab Sample ID: J0J2222-50	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0115	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2003	LLW

Client Sample ID: Girl's 4th Grade BR Sink #1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:50
Lab Sample ID: J0J2222-51	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2005	LLW

Client Sample ID: Girl's 4th Grade BR Sink #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:51
Lab Sample ID: J0J2222-52	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2008	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Girl's 4th Grade BR Sink #3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:53
Lab Sample ID: J0J2222-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2010	LLW

Client Sample ID: 4th Grade Fountain Left	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:53
Lab Sample ID: J0J2222-54	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2012	LLW

Client Sample ID: Boy's 4th Grade BR Sink #1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:55
Lab Sample ID: J0J2222-55	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2014	LLW

Client Sample ID: Boy's 4th Grade BR Sink #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:55
Lab Sample ID: J0J2222-56	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2020	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Boy's 4th Grade BR Sink #3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:56
Lab Sample ID: J0J2222-57	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2022	LLW

Client Sample ID: Room 20	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 6:59
Lab Sample ID: J0J2222-58	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0150 AL	0.0010	mg/L		11/04/20 1517	11/04/20 2024	LLW

Client Sample ID: Room 18	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:00
Lab Sample ID: J0J2222-59	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.0150 AL	0.0010	mg/L		11/05/20 1429	11/05/20 2100	LLW

Client Sample ID: Bus Garage Staff Break Rm Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:05
Lab Sample ID: J0J2222-60	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0088	0.0150 AL	0.0010	mg/L		11/05/20 1429	11/05/20 2102	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J2222

Client Sample ID: Bus Garage Staff BR Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/28/2020 7:06
Lab Sample ID: J0J2222-61	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0099	0.0150 AL	0.0010	mg/L		11/05/20 1429	11/05/20 2122	LLW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- D:** The sample was diluted due to matrix interference.
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.**

Reviewed and Approved By:

Jennifer Walker
 Operations Manager
 Reported: 11/18/2020 09:54

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 2 Level 3 Level 4 EDD

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No

Agency/Program

PO No.:

Sampler Phone No.: (607) 240-3966

Sampler Signature:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional
	Room 6 Sink #1 - R+	10/28/20	6:21	1	DW	G	U	
	Room 6 Sink #2 - L+	10/28/20	6:21	1	DW	G	U	
	Room 3	10/28/20	6:22	1	DW	G	U	
	Room 1	10/28/20	6:23	1	DW	G	U	
	Room 2	10/28/20	6:25	1	DW	G	U	
	5th Grade Staff BR	10/28/20	6:27	1	DW	G	U	
	Staff Breakroom	10/28/20	6:28	1	DW	G	U	
	5th Grade Boy's BR Sink #1 - f	10/28/20	6:29	1	DW	G	U	
	5th Grade Boy's BR Sink #2	10/28/20	6:29	1	DW	G	U	
	5th Grade Boy's BR Sink #3	10/28/20	6:29	1	DW	G	U	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Comments

Please email to DKendall@greenebsd.org

Relinquished By (signature)

Date/Time

933

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

933

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

933

Received By (signature)

Date/Time

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 1 Level 2 Level 3 Level 4 EDD

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No

Agency/Program

PO No.:

Sampler Phone No.: (607) 240-3966

Invoice Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Lab Report Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via: Mail Fax e-mail (address)

Location:

Sampler Signature:

PO No.:

Sampler Phone No.: (607) 240-3966

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (9) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	Fountain 5th Grade Left	10/28/20	6:30	1	DW	G	U	LEAD
	Fountain 5th Grade Right	10/28/20	6:30	1	DW	G	U	LEAD
	5th Grade Girl's BR Sink #1	10/28/20	6:31	1	DW	G	U	LEAD
	5th Grade Girl's BR Sink #2	10/28/20	6:31	1	DW	G	U	LEAD
	5th Grade Girl's Br Sink #3	10/28/20	6:31	1	DW	G	U	LEAD
	Room 10	10/28/20	6:32	1	DW	G	U	LEAD
	Room 12	10/28/20	6:34	1	DW	G	U	LEAD
	Room 14	10/28/20	6:34	1	DW	G	U	LEAD
	Room 16	10/28/20	6:37	1	DW	G	U	LEAD
	Room 13	10/28/20	6:38	1	DW	G	U	LEAD

Possible Hazard Identification

Hazardous Non-Hazardous

Radioactive

Sample Disposition

Dispose as appropriate Return Archive

Comments

Please email to DKendall@greenebsd.org

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 1 Level 2 Level 3 Level 4 EDD

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No

Agency/Program

Sampler Phone No.: (607) 240-3966

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Invoice Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Lab Report Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via: Mail Fax e-mail (address)

Location:

Sampler Signature:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	Room 11	10/28/20	6:39	1	DW	G	U	LEAD
	Room 9	10/28/20	6:41	1	DW	G	U	LEAD
	Room 7	10/28/20	6:42	1	DW	G	U	LEAD
	Girl's Locker Room Sink	10/28/20	6:44	1	DW	G	U	LEAD
	Girl's Coach's Office Sink	10/28/20	6:45	1	DW	G	U	LEAD
	Main Office BR Sink	10/28/20	6:46	1	DW	G	U	LEAD
	Nurse's Office Sink	10/28/20	6:47	1	DW	G	U	LEAD
	Nurse's BR Sink	10/28/20	6:48	1	DW	G	U	LEAD
	Boy's Locker Room Sink	10/28/20	6:49	1	DW	G	U	LEAD
	Boy's Coach's Office Sink	10/28/20	6:50	1	DW	G	U	LEAD

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Comments

Please email to DKendall@greeneccsd.org

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

CHAIN OF CUSTODY RECORD

Number _____
Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) _____
Therm ID _____
Holding Time _____
Samples Received on Ice? Yes No N/A
Custody Seals Intact? Yes No N/A

Turnaround Time _____

Routine (5 to 7 business days)
 RUSH* (notify lab)

(needed by) _____

Report Type _____

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address) _____

Compliance Monitoring? Yes No
 Agency/Program

Sampler Phone No.: (607) 240-3966

Invoice Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Lab Report Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via: Mail Fax e-mail (address) _____

Project: _____ Location: _____ PO No.: _____

Sampler Signature: _____

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	Kitchen Sink	10/28/20	6:19	1	DW	G	U	LEAD
	Gym Foyer Fountain left	10/28/20	6:21	1	DW	G	U	LEAD
	Gym Foyer Fountain Right	10/28/20	6:21	1	DW	G	U	LEAD
	Gym Foyer Boy's BR Sink 1 Left	10/28/20	6:23	1	DW	G	U	LEAD
	Gym Foyer Boy's Sink 2 Right	10/28/20	6:23	1	DW	G	U	LEAD
	Gym Foyer Girl's BR Sink 1 Left	10/28/20	6:25	1	DW	G	U	LEAD
	Gym Foyer Girl's BR Sink 2 Right	10/28/20	6:25	1	DW	G	U	LEAD
	Gym Fountain-Left	10/28/20						
	Gym Fountain Right	10/28/20	6:27	1	DW	G	U	LEAD
	4th Grade Staff BR	10/28/20	6:30	1	DW	G	U	LEAD

Sample Disposition Dispose as appropriate Return Archive

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments: Please email to DKendall@greenecsd.org

Relinquished By (signature) *[Signature]* Date/Time 10/28 9:33

Relinquished By (signature) _____ Date/Time _____

Relinquished By (signature) _____ Date/Time _____

Relinquished By (signature) _____ Date/Time _____

CHAIN OF CUSTODY RECORD

Number *Instructions on back*

TO BE COMPLETED BY MICROBAC
 Temperature Upon Receipt (°C)
 Therm ID
 Holding Time
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 (needed by)
 Report Type
 Results Only Level 1 Level 2 Level 3 Level 4 EDD

Invoice Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall

Lab Report Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall

Telephone No.: (607) 240-3966
 Send Report via: Mail Fax e-mail (address)
 Location:
 Project:
 Compliance Monitoring? Yes No
 Agency/Program

Send Invoice via: Mail Fax e-mail (address)
 PO No.:
 Sampler Phone No.: (607) 240-3966

Sampler Signature:
 Telephone No.: (607) 240-3966

Sampler Signature:
 Telephone No.: (607) 240-3966

Sampler Signature:
 Telephone No.: (607) 240-3966

Sample Disposition Dispose as appropriate Return Archive

Sample Disposition Dispose as appropriate Return Archive

Sample Disposition Dispose as appropriate Return Archive

Sample Disposition Dispose as appropriate Return Archive

Sample Disposition Dispose as appropriate Return Archive

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	Room 19	10/28/20	6:30	1	DW	G	U	LEAD
	Room 21	10/28/20	6:33	1	DW	G	U	LEAD
	Room 23	10/28/20	6:35	1	DW	G	U	LEAD
	Room 25	10/28/20	6:37	1	DW	G	U	LEAD
	Room 27	10/28/20	6:38	1	DW	G	U	LEAD
	Room 24	10/28/20	6:40	1	DW	G	U	LEAD
	Room 29	10/28/20	6:42	1	DW	G	U	LEAD
	Room 31	10/28/20	6:43	1	DW	G	U	LEAD
	Room 30	10/28/20	6:45	1	DW	G	U	LEAD
	Room 28	10/28/20	6:47	1	DW	G	U	LEAD

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Non-Hazardous Radioactive

Relinquished By (signature) *[Signature]* Date/Time 10/28 9:53
 Relinquished By (signature) *[Signature]* Date/Time
 Relinquished By (signature) *[Signature]* Date/Time

Received By (signature) Date/Time
 Received By (signature) Date/Time
 Received By (signature) Date/Time

CHAIN OF CUSTODY RECORD

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Instructions on back

TO BE COMPLETED BY MICROBAC
 Temperature Upon Receipt (°C) Therm ID
 Holding Time
 Samples Received on Ice? Yes No N/A
 Custody Seals Intact? Yes No N/A

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 (needed by)
 Report Type
 Results Only Level 1 Level 2 Level 3 Level 4 EDD

Invoice Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall
 Telephone No.: (607) 240-3966

Lab Report Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall
 Telephone No.: (607) 240-3966

Send Report via: Mail Fax e-mail (address)
 Send Invoice via: Mail Fax e-mail (address)
 PO No.: Agency/Program
 Compliance Monitoring? Yes No

Sampled by (PRINT): Mail Fax e-mail (address) PO No.: Agency/Program
 Sampler Signature: Sampler Phone No.: (607) 240-3966

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	Room 22	10/28/20	6:49	1	DW	G	U	
	Girl's 4th Grade BR Sink #1	10/28/20	6:50	1	DW	G	U	
	Girl's 4th Grade BR Sink #2	10/28/20	6:51	1	DW	G	U	
	Girl's 4th Grade BR Sink #3	10/28/20	6:53	1	DW	G	U	
	4th Grade Fountain Left	10/28/20	6:53	1	DW	G	U	
	4th Grade Fountain Right	10/28/20		1	DW	G	U	
	Boy's 4th Grade BR Sink #1	10/28/20	6:55	1	DW	G	U	
	Boy's 4th Grade BR Sink #2	10/28/20	6:55	1	DW	G	U	
	Boy's 4th Grade BR Sink #3	10/28/20	6:56	1	DW	G	U	
	Room 20	10/28/20	6:59	1	DW	G	U	

Requested Analysis
 Sample Disposition: Dispose as appropriate Return Archive
 Relinquished By (signature) Date/Time 10/28 9:33
 Relinquished By (signature) Date/Time
 Relinquished By (signature) Date/Time

CHAIN OF CUSTODY RECORD

Number

Instructions on back

Lab Report Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall
 Telephone No.: (607) 240-3966

Invoice Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall
 Telephone No.: (607) 240-3966

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 (needed by)
Report Type
 Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Report via: Mail Fax e-mail (address)

Send Invoice via: Mail Fax e-mail (address)

Location: PO No.:

Compliance Monitoring? Yes No
 Agency/Program

Sampler Signature: **Sampler Phone No.:** (607) 240-3966

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

19.4

044

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	Room 18	10/28/20	7:00	1	DW	G	U	
	Bus Garage Staff Break Rm Sint	10/28/20	7:05	1	DW	G	U	
	Bus Garage Staff BR Sink	10/28/20	7:06	1	DW	G	U	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Comments
 Please email to DKendall@greeneccsd.org
 Relinquished By (signature) *[Signature]* Date/Time 10/28/20 9:33
 Relinquished By (signature) *[Signature]* Date/Time
 Relinquished By (signature) *[Signature]* Date/Time

Received By (signature) *[Signature]* Date/Time 10/28/2020 9:46
 Received By (signature) *[Signature]* Date/Time

Received By (signature) *[Signature]* Date/Time