



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Greene Central School

Project Name: Lead Water Testing

Dave Kendall
40 South Canal Street
Greene, NY 13778

Project / PO Number: N/A
Received: 10/14/2020
Reported: 11/04/2020

Analytical Testing Parameters

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include Bldg 3DN Business Office, Drinking Water, J0J1427-01, Customer, 10/14/2020 6:10.

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0060, 0.0150 AL, 0.0010, mg/L, 10/27/20 1522, 10/28/20 1053, LLW.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include Bldg 3DN Board Room, Drinking Water, J0J1427-02, Customer, 10/14/2020 6:55.

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0093, 0.0150 AL, 0.0010, mg/L, 10/27/20 1522, 10/28/20 1058, LLW.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include Bldg 3DN Left Fountain Aud., Drinking Water, J0J1427-03, Customer, 10/14/2020 6:15.

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0031, 0.0150 AL, 0.0010, mg/L, 10/27/20 1522, 10/28/20 1100, LLW.

Table with 4 columns: Client Sample ID, Sample Matrix, Lab Sample ID, Collected By, Collection Date. Values include Bldg 3DN Right Fountain Aud., Drinking Water, J0J1427-04, Customer, 10/14/2020 6:15.

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Table with 9 columns: Metals Total by ICPMS, Result, Limit(s), RL, Units, Note, Prepared, Analyzed, Analyst. Row for Lead: 0.0037, 0.0150 AL, 0.0010, mg/L, 10/27/20 1522, 10/28/20 1102, LLW.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 3DN Fountain by Girls BR	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:17
Lab Sample ID: J0J1427-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1104	LLW

Client Sample ID: Bldg 3DN Fountain by Boys BR	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:18
Lab Sample ID: J0J1427-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1106	LLW

Client Sample ID: Bldg 3DN Staff Bathroom	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:20
Lab Sample ID: J0J1427-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0213	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1111	LLW

Client Sample ID: Bldg 3DN Staff Break Room	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:20
Lab Sample ID: J0J1427-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0110	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1113	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 3DN Room 120	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:25
Lab Sample ID: J0J1427-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.103	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1115	LLW

Client Sample ID: Bldg 3DN Room 121	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:25
Lab Sample ID: J0J1427-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1117	LLW

Client Sample ID: Bldg 3DN MS Office BR	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:30
Lab Sample ID: J0J1427-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0087	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1119	LLW

Client Sample ID: Bldg 3DN Ms Office Kitchen	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:30
Lab Sample ID: J0J1427-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0065	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1122	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 4DN Left Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:40
Lab Sample ID: J0J1427-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1124	LLW

Client Sample ID: Bldg 4DN Right Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:40
Lab Sample ID: J0J1427-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1126	LLW

Client Sample ID: Bldg 4UP Room 222 R of Door	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:45
Lab Sample ID: J0J1427-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1128	LLW

Client Sample ID: Bldg 4UP RM 222 Next to fridg	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:45
Lab Sample ID: J0J1427-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0043	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1133	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 4UP RM 222 Front of Door	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:45
Lab Sample ID: J0J1427-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0074	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1135	LLW

Client Sample ID: Bldg 4UP RM 222	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:45
Lab Sample ID: J0J1427-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1137	LLW

Client Sample ID: Bldg 4UP Staff Bathroom	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:50
Lab Sample ID: J0J1427-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0072	0.0150 AL	0.0010	mg/L		10/27/20 1522	10/28/20 1139	LLW

Client Sample ID: Bldg 4UP North Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:50
Lab Sample ID: J0J1427-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.104	0.0150 AL	0.0010	mg/L		10/28/20 1234	10/28/20 1543	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 3UP Room 221	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:11
Lab Sample ID: J0J1427-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1314	LLW

Client Sample ID: Bldg 3UP Room 220 MS Library	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:16
Lab Sample ID: J0J1427-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0104	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1320	LLW

Client Sample ID: Bldg 3UP Staff Bathroom	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:18
Lab Sample ID: J0J1427-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1321	LLW

Client Sample ID: Bldg 3UP Fountain next to 215	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:20
Lab Sample ID: J0J1427-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1323	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 Room 112 Band Room	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:23
Lab Sample ID: J0J1427-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1325	LLW

Client Sample ID: Bldg 2 Girls HS Locker Rm #1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:26
Lab Sample ID: J0J1427-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1327	LLW

Client Sample ID: Bldg 2 Girls HS Locker Rm #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:26
Lab Sample ID: J0J1427-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0126	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1332	LLW

Client Sample ID: Bldg 2 Girls HS Locker Room	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:28
Lab Sample ID: J0J1427-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0302	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1334	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 Concession Stand	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:30
Lab Sample ID: J0J1427-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1336	LLW

Client Sample ID: Bldg 2 MS Coach"s Office Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:32
Lab Sample ID: J0J1427-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1338	LLW

Client Sample ID: Bldg 2 Girls MS LR L/Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:34
Lab Sample ID: J0J1427-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0059	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1340	LLW

Client Sample ID: Bldg 2 Girls MS LR R/Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:34
Lab Sample ID: J0J1427-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0231	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1343	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 Kitchen Hand Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:37
Lab Sample ID: J0J1427-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0271	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1345	LLW

Client Sample ID: Bldg 2 Kitchen H/Sink by DW	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:37
Lab Sample ID: J0J1427-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1347	LLW

Client Sample ID: Bldg 2 Kitchen H/Sink by SR	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:37
Lab Sample ID: J0J1427-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0011	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1349	LLW

Client Sample ID: Bldg 2 Kitchen Slnk by Clock	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:41
Lab Sample ID: J0J1427-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0338	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1354	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 Kitchen Sink by Mixer	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:42
Lab Sample ID: J0J1427-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1356	LLW

Client Sample ID: Bldg 2 Kitchen Sink across from	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:44
Lab Sample ID: J0J1427-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1358	LLW

Client Sample ID: Bldg 2 Kitchen H/Sink next to 39	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:46
Lab Sample ID: J0J1427-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0072	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1400	LLW

Client Sample ID: Bldg 2 Kitchen BR Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:49
Lab Sample ID: J0J1427-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0340	0.0150 AL	0.0010	mg/L		10/27/20 1523	10/28/20 1402	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 Boys Pool LR Sink #1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:08
Lab Sample ID: J0J1427-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0241	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1411	LLW

Client Sample ID: Bldg 2 Boys Pool LR Sink #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:10
Lab Sample ID: J0J1427-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0129	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1416	LLW

Client Sample ID: Bldg 2 Boys Pool LR Sink #3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:11
Lab Sample ID: J0J1427-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0063	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1418	LLW

Client Sample ID: Bldg 2 Girls Pool LR Sink #1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:12
Lab Sample ID: J0J1427-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0062	0.0150 AL	0.0010	mg/L		10/28/20 1352	10/29/20 1410	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 Girls Pool LR Sink #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:13
Lab Sample ID: J0J1427-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0109	0.0150 AL	0.0010	mg/L		10/28/20 1352	10/29/20 1412	LLW

Client Sample ID: Bldg 2 Girls Pool LR Sink #3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:14
Lab Sample ID: J0J1427-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0055	0.0150 AL	0.0010	mg/L		10/28/20 1352	10/29/20 1413	LLW

Client Sample ID: Bldg 2 Pool Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:17
Lab Sample ID: J0J1427-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1420	LLW

Client Sample ID: Bldg 2 Custodian Office Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:20
Lab Sample ID: J0J1427-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0089	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1422	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 MS BLR L/Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:23
Lab Sample ID: J0J1427-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0134	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1424	LLW

Client Sample ID: Bldg 2 MS BLR R/Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:22
Lab Sample ID: J0J1427-50	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0093	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1429	LLW

Client Sample ID: Bldg 2 MS BLR Office Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:24
Lab Sample ID: J0J1427-51	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0025	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1431	LLW

Client Sample ID: Bldg 2 Girls Side Fountain	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:27
Lab Sample ID: J0J1427-52	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1433	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 Rm 110 Trainers Off. Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:29
Lab Sample ID: J0J1427-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1435	LLW

Client Sample ID: Bldg 2 Boys Public BR Sink #1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:31
Lab Sample ID: J0J1427-54	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1436	LLW

Client Sample ID: Bldg 2 Boys Public BR Sink #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:32
Lab Sample ID: J0J1427-55	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0013	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1440	LLW

Client Sample ID: Bldg 2 Boys Public BR Sink #3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:32
Lab Sample ID: J0J1427-56	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1442	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 Boys Public BR Sink #4	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:32
Lab Sample ID: J0J1427-57	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1444	LLW

Client Sample ID: Bldg 2 Girls Public BR Sink #1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:36
Lab Sample ID: J0J1427-58	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1446	LLW

Client Sample ID: Bldg 2 Girls Public BR Sink #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:37
Lab Sample ID: J0J1427-59	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1451	LLW

Client Sample ID: Bldg 2 Girls Public BR Sink #3	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:37
Lab Sample ID: J0J1427-60	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1453	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 2 Girls Public BR Sink #4	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:37
Lab Sample ID: J0J1427-61	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1455	LLW

Client Sample ID: Bldg 2 Boys HS LR R/Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:42
Lab Sample ID: J0J1427-62	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0059	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1457	LLW

Client Sample ID: Bldg 2 Bosity HS LR L/Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:42
Lab Sample ID: J0J1427-63	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0078	0.0150 AL	0.0010	mg/L		10/27/20 1524	10/28/20 1458	LLW

Client Sample ID: Bldg 2 Boys HS LR Office Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:43
Lab Sample ID: J0J1427-64	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0063	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2110	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 1 DN Rm 114 Nurs BR	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:46
Lab Sample ID: J0J1427-65	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2116	LLW

Client Sample ID: Bldg 1 DN Nurses Office Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:47
Lab Sample ID: J0J1427-66	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0020	0.0150 AL	0.0020	mg/L		10/27/20 1511	10/28/20 1237	LLW

Client Sample ID: Bldg 1 DN FOuntain by HS Off.	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:49
Lab Sample ID: J0J1427-67	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2119	LLW

Client Sample ID: Bldg 1 DN HS Office Kitchen	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:51
Lab Sample ID: J0J1427-68	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2121	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 1 DN HS Office BR	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:52
Lab Sample ID: J0J1427-69	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/28/20 1234	10/28/20 1548	LLW

Client Sample ID: Bldg 1DN Library Kitchen Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:54
Lab Sample ID: J0J1427-70	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0197	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2123	LLW

Client Sample ID: Bldg 1 DN Fountain by RM 130	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:58
Lab Sample ID: J0J1427-71	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2129	LLW

Client Sample ID: Bldg 1DN Staff BR	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:59
Lab Sample ID: J0J1427-72	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.0150 AL	0.0010	mg/L		10/28/20 1352	10/29/20 1419	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 1 DN Staff Lounge Sink	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 7:01
Lab Sample ID: J0J1427-73	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0074	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2131	LLW

Client Sample ID: Bldg 1UP Room 203	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 7:03
Lab Sample ID: J0J1427-74	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0097	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2133	LLW

Client Sample ID: Bldg 1UP Fountain East	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 7:05
Lab Sample ID: J0J1427-75	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.0150 AL	0.0010	mg/L		10/28/20 1352	10/29/20 1421	LLW

Client Sample ID: Bldg 1UP Fountain West #1	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 7:07
Lab Sample ID: J0J1427-76	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2135	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Client Sample ID: Bldg 1UP Fountain West #2	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 7:07
Lab Sample ID: J0J1427-77	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2137	LLW

Client Sample ID: Bldg 1 UP Staff Bathroom	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 7:09
Lab Sample ID: J0J1427-78	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0023	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2141	LLW

Client Sample ID: Bldg 1UP Room 236	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 7:11
Lab Sample ID: J0J1427-79	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.0150 AL	0.0010	mg/L		10/27/20 1511	10/27/20 2143	LLW

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL:** US EPA Action Level
- mg/L:** Milligrams per Liter
- RL:** Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1427

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in black ink that reads "Shannon Weeks".

Shannon Weeks

Customer Relationship Coordinator

Reported: 11/04/2020 19:04

CHAIN OF CUSTODY RECORD
 Number _____
 Instructions on back

TO BE COMPLETED BY MICROBAC
 Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 (needed by) _____
 Report Type _____
 Results Only Level 1 Level 2 Level 3 Level 4 EDD
 Mail Fax e-mail (address)
 Send Invoice via: _____ PO No.: _____
 Compliance Monitoring? Yes No
 Agency/Program

Lab Report Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall
 Telephone No.: (607) 240-3966
 Send Report via: Mail Fax e-mail (address)
 Project: _____

Invoice Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall
 Telephone No.: (607) 240-3966
 Location: _____
 Sampler Signature: *Brandon Simonds*
 Sampler Phone No.: (607) 240-3966

Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall
 Telephone No.: (607) 240-3966
 Send Report via: Mail Fax e-mail (address)
 Project: _____
 Location: _____
 Sampler Signature: *Brandon Simonds*
 Sampler Phone No.: (607) 240-3966

Sampled by (PRINT): *Brandon Simonds*
 * Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **	Sample Disposition	Date/Time
	Bldg 3DN Business Office	10/14/20	6:10	1	DW	U	LEAD	
	Bldg 3DN Board Room	10/14/20	6:55	1	DW	U	LEAD	
	Bldg 3DN Left Fountain Aud.	10/14/20	6:15	1	DW	U	LEAD	
	Bldg 3DN Right Fountain Aud.	10/14/20	6:15	1	DW	U	LEAD	
	Bldg 3DN Fountain by Girls BR	10/14/20	6:17	1	DW	U	LEAD	
	Bldg 3DN Fountain by Boys BR	10/14/20	6:18	1	DW	U	LEAD	
	Bldg 3DN Staff Bathroom	10/14/20	6:20	1	DW	U	LEAD	
	Bldg 3DN Staff Break Room	10/14/20	6:20	1	DW	U	LEAD	
	Bldg 3DN Room 120	10/14/20	6:25	1	DW	U	LEAD	
	Bldg 3DN Room 121	10/14/20	6:25	1	DW	U	LEAD	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive
 Comments: _____
 Relinquished By (signature) _____ Date/Time _____
 Relinquished By (signature) _____ Date/Time _____
 Relinquished By (signature) _____ Date/Time _____
 Received By (signature) _____ Date/Time _____
 Received By (signature) _____ Date/Time _____
 Received By (signature) _____ Date/Time _____
 Disposition as appropriate Return Archive



Greene Central School
 PM: Shannon Weeks

CHAIN OF CUSTODY RECORD

Number
Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time

Temperature Upon Receipt (°C)
Therm ID

Routine (5 to 7 business days)
 RUSH* (notify lab)

Holding Time

(needed by)

Samples Received on Ice? Yes No N/A

Report Type

Custody Seals Intact? Yes No N/A

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address)

Send Invoice via: Mail Fax e-mail (address)

Project:

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No

Location:

Agency/Program

Sampled by (PRINT): *Brandon Simonds* Sampler Signature: *Brandon Simonds* Sampler Phone No.: (607) 240-3966

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grat / Comp	Preservative Types **	Sample Disposition	Additional Notes
	Bldg 3DN MS Office BR	10/14/20	6:30	1	DW	G	U	LEAD	
	Bldg 3DN MS Office Kitchen	10/14/20	6:30	1	DW	G	U	LEAD	
	Bldg 4DN Left Fountain	10/14/20	6:40	1	DW	G	U	LEAD	
	Bldg 4DN Right Fountain	10/14/20	6:40	1	DW	G	U	LEAD	
	Bldg 4UP Room 222 R of Door	10/14/20	6:45	1	DW	G	U	LEAD	
	Bldg 4UP RM 222 Next to fridg	10/14/20	6:45	1	DW	G	U	LEAD	
	Bldg 4UP RM 222 Front of Door	10/14/20	6:45	1	DW	G	U	LEAD	
	Bldg 4UP RM 222	10/14/20	6:45	1	DW	G	U	LEAD	Across from Fridge
	Bldg 4UP Staff Bathroom	10/14/20	6:50	1	DW	G	U	LEAD	
	Bldg 4UP North Fountain	10/14/20	6:50	1	DW	G	U	LEAD	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Return Archive

Comments: Please email to DKendall@GreeneCSD.ORG

Relinquished By (signature) Date/Time Received By (signature) Date/Time

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 1 Level 2 Level 3 Level 4 EDD

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No

Agency/Program

Sampler Phone No.: (607) 240-3966

Sampler Signature: *Nick Straniero*

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Sample Disposition	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time	Additional Notes	
	Bldg 3UP Room 221	10/14/20	6:11	1	DW	G	U	LEAD						
	Bldg 3UP Room 220 MS Library	10/14/20	6:16	1	DW	G	U	LEAD						
	Bldg 3UP Staff Bathroom	10/14/20	6:18	1	DW	G	U	LEAD						
	Bldg 3UP Fountain next to 215	10/14/20	6:20	1	DW	G	U	LEAD						
	Bldg 2 Room 112 Band Room	10/14/20	6:23	1	DW	G	U	LEAD						
	Bldg 2 Girls HS Locker Rm #1	10/14/20	6:26	1	DW	G	U	LEAD					Sink #1	
	Bldg 2 Girls HS Locker Rm #2	10/14/20	6:26	1	DW	G	U	LEAD					Sink #2	
	Bldg 2 Girls HS Locker Room	10/14/20	6:28	1	DW	G	U	LEAD					Office Sink	
	Bldg 2 Concession Stand	10/14/20	6:30	1	DW	G	U	LEAD						
	Bldg 2 MS Coach's Office Sink	10/14/20	6:32	1	DW	G	U	LEAD						
Possible Hazard Identification <input type="checkbox"/> Hazardous <input checked="" type="checkbox"/> Non-Hazardous <input type="checkbox"/> Radioactive										Sample Disposition	Dispose as appropriate <input checked="" type="checkbox"/> Return <input type="checkbox"/> Archive			
Comments										Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time	
Please email to DKendall@GreeneCSD.ORG										Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time	
										Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time	

MICROBAC* 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Lab Report Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY, 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via: Mail Fax e-mail (address)

Project:

Sampled by (PRINT): *Nick Straniero*

Sampler Signature: *Nick Straniero*

Location:

PO No.:

Sampler Phone No.: (607) 240-3966

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

CHAIN OF CUSTODY RECORD

Number *Instructions on back* TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 1 Level 2 Level 3 Level 4 EDD

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

(needed by) Report Type

Results Only

Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via:

Mail Fax e-mail (address)

Compliance Monitoring?

Yes No

Agency/Program

Sampler Phone No.: (607) 240-3966

Location:

PO No. *AS Group*

Sampler Signature:

Nick Staniezo

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Requested Analysis

Requested Analysis

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Sample Disposition	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time	Additional Notes
	Bldg 2 Girls MS LR L/Sink	10/14/20	6:34	1	DW	G	U	<input checked="" type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive					Sink by Dishwasher
	Bldg 2 Girls MS LR R/Sink	10/14/20	6:34	1	DW	G	U						Sink by Store Room
	Bldg 2 Kitchen Hand Sink	10/14/20	6:37	1	DW	G	U						Roll Up Doors
	Bldg 2 Kitchen H/Sink By DW	10/14/20	6:37	1	DW	G	U						Sink next to sink #39
	Bldg 2 Kitchen H/Sink By SR	10/14/20	6:41	1	DW	G	U						
	Bldg 2 Kitchen Sink by Clock	10/14/20	6:41	1	DW	G	U						
	Bldg 2 Kitchen Sink by Mixer	10/14/20	6:42	1	DW	G	U						
	Bldg 2 Kitchen Sink across from	10/14/20	6:44	1	DW	G	U						
	Bldg 2 Kitchen H/Sink next to 38	10/14/20	6:46	1	DW	G	U						
	Bldg 2 Kitchen BR Sink	10/14/20	6:49	1	DW	G	U						

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 2 Level 3 Level 4 EDD

Turnaround Time

Routine (5 to 7 business days)

RUSH* (notify lab)

(needed by)

Report Type

Results Only Level 1 Level 2 Level 3

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No

Agency/Program

Sampler Phone No.: (607) 240-3966

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Invoice Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via: Mail Fax e-mail (address)

Location:

PO No.:

Sampler Signature: *Dave Kendall*

Dave Kendall

Lab Report Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY, 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via: Mail Fax e-mail (address)

Project:

Sampled by (PRINT): *Dave Kendall*

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Preservative Types **	Grab / Comp	Sample Disposition	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time	Additional Notes
	Bldg 2 Boys Pool LR Sink #1	10/14/20	6:04	1	DW	U	G	<input checked="" type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive	<i>Dave Kendall</i>				BR Sink #1
	Bldg 2 Boys Pool LR Sink #2	10/14/20	6:10	1	DW	U	G						BR Sink #2
	Bldg 2 Boys Pool LR Sink #3	10/14/20	6:11	1	DW	U	G						BR Sink #3
	Bldg 2 Girls Pool LR Sink #1	10/14/20	6:12	1	DW	U	G						GR Sink #1
	Bldg 2 Girls Pool LR Sink #2	10/14/20	6:13	1	DW	U	G						GR Sink #2
	Bldg 2 Girls Pool LR Sink #3	10/14/20	6:14	1	DW	U	G						GR Sink #3
	Bldg 2 Pool Fountain	10/14/20	6:17	1	DW	U	G						
	Bldg 2 Custodian Office Sink	10/14/20	6:20	1	DW	U	G						Left Sink
	Bldg 2 MS BLR L/Sink	10/14/20	6:23	1	DW	U	G						Right Sink
	Bldg 2 MS BLR R/Sink	10/14/20	6:22	1	DW	U	G						

Possible Hazard Identification Hazardous Non-Hazardous Radioactive

Comments

Please email to DKendall@GreeneCSD.ORG

CHAIN OF CUSTODY RECORD

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Recalved on Ice? Yes No N/A

Custody Seals Intact? Yes No N/A

Level 1 Level 2 Level 3 Level 4 EDD

Compliance Monitoring? Yes No

Agency/Program

Sampler Phone No.: (607) 240-3966

Matrix Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (9) Unpreserved

Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (9) Unpreserved

Requested Analysis

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

MICROBAC 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Lab Report Address

Client Name: Greene Central School District

Address: 40 South Canal St.

City, State, Zip: Greene, NY, 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via: Mail Fax e-mail (address)

Project:

Location:

PO No.:

Compliance Monitoring? Yes No

Agency/Program

Sampled by (PRINT): *Dave Kendall*

Sampler Signature: *Dave Kendall*

Sampler Phone No.: (607) 240-3966

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Hexane, (9) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Sample Disposition	Additional Notes
	Bldg 2 MS BLR Office Sink	10/14/20	6:24	1	DW	G	U	LEAD	Trainers Office Sink
	Bldg 2 Girls Side Fountain	10/14/20	6:27	1	DW	G	U	LEAD	Boys Public BR Sink #1
	Bldg 2 Rm 110 Trainers Off. Sini	10/14/20	6:29	1	DW	G	U	LEAD	Boys Public BR Sink #2
	Bldg 2 Boys Public BR Sink #1	10/14/20	6:31	1	DW	G	U	LEAD	Boys Public BR Sink #3
	Bldg 2 Boys Public BR Sink #2	10/14/20	6:32	1	DW	G	U	LEAD	Boys Public BR Sink #4
	Bldg 2 Boys Public BR Sink #3	10/14/20	6:32	1	DW	G	U	LEAD	Girls Public BR Sink #1
	Bldg 2 Boys Public BR Sink #4	10/14/20	6:32	1	DW	G	U	LEAD	Girls public BR Sink #2
	Bldg 2 Girls Public BR Sink #1	10/14/20	6:36	1	DW	G	U	LEAD	Girls Public BR Sink #3
	Bldg 2 Girls Public BR Sink #2	10/14/20	6:37	1	DW	G	U	LEAD	
	Bldg 2 Girls Public BR Sink #3	10/14/20	6:37	1	DW	G	U	LEAD	

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Dispose as appropriate Return Archive

Comments

Please email to DKendall@GreeneCSD.ORG

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

CHAIN OF CUSTODY RECORD

Number _____ Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address: Client Name: Greene Central School District
 Invoice Address: Client Name: Greene Central School District
 Address: 40 South Canal St. Address: 40 South Canal St.
 City, State, Zip: Greene, NY, 13778 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall Contact: Dave Kendall
 Telephone No.: (607) 240-3966 Telephone No.: (607) 240-3966
 Send Report via: Mail Fax e-mail (address) Send Invoice via: Mail Fax e-mail (address)

Project: Location: PO No.: Compliance Monitoring? Yes No
 Agency/Program Agency/Program

Sampled by (PRINT): **Dave Kendall** Sampler Signature: *Dave Kendall* Sampler Phone No.: (607) 240-3966

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Sample Disposition	Relinquished By (signature)	Date/Time	Received By (signature)	Date/Time	Additional Notes
	Bldg 2 Girls Public BR Sink #4	10/14/20	6:37	1	DW	G	U	LEAD					Girls Public BR Sink #4
	Bldg 2 Boys HS LR R/Sink	10/14/20	6:42	1	DW	G	U	LEAD					Boys HS LR Right Sink
	Bldg 2 Boys HS LR L/Sink	10/14/20	6:42	1	DW	G	U	LEAD					Boys HS LR Left Sink
	Bldg 2 Boys HS LR Office Sink	10/14/20	6:43	1	DW	G	U	LEAD					Boys HS LR Office Sink
	Bldg 1DN Rm 114 Nurses BR	10/14/20	6:46	1	DW	G	U	LEAD					Nurses Office BR Sink
	Bldg 1DN Nurses Office Sink	10/14/20	6:47	1	DW	G	U	LEAD					Fountain by HS Office
	Bldg 1DN Fountain by HS Off.	10/14/20	6:49	1	DW	G	U	LEAD					
	Bldg 1DN HS Office Kitchen	10/14/20	6:51	1	DW	G	U	LEAD					
	Bldg 1DN HS Office BR	10/14/20	6:52	1	DW	G	U	LEAD					
	Bldg 1DN Library Kitchen Sink	10/14/20	6:54	1	DW	G	U	LEAD					

CHAIN OF CUSTODY RECORD

Number *Instructions on back*

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C) **20.6**
 Therm ID
 Holding Time
 Samples Received on Ice? Yes No **N/A**
 Custody Seals Intact? Yes No **N/A**

Turnaround Time
 Routine (5 to 7 business days)
 RUSH* (notify lab)
 (needed by)
 Report Type
 Results Only Level 1 Level 2 Level 3 Level 4 EDD

Invoice Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY 13778
 Contact: Dave Kendall
 Telephone No.: (607) 240-3966

Lab Report Address
 Client Name: Greene Central School District
 Address: 40 South Canal St.
 City, State, Zip: Greene, NY, 13778
 Contact: Dave Kendall
 Telephone No.: (607) 240-3966

Send Invoice via: Mail Fax e-mail (address)
 PO No.:
 Compliance Monitoring? Yes No
 Agency/Program

Location:
 Sampler Signature: *Dave Kendall*
 Sampler Phone No.: (607) 240-3966

Project:
 Relinquished By (signature) *Dave Kendall*
 Date/Time

Sampled by (PRINT): **Dave Kendall**
 * Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
 ** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	Bldg 1DN Fountain by RM 130	10/14/20	6:58	1	DW	G	U	LEAD
	Bldg 1DN Staff BR	10/14/20	6:59	1	DW	G	U	LEAD
	Bldg 1DN Staff Lounge Sink	10/14/20	7:01	1	DW	G	U	LEAD
	Bldg 1UP Room 203	10/14/20	7:03	1	DW	G	U	LEAD
	Bldg 1UP Fountain East	10/14/20	7:05	1	DW	G	U	LEAD
	Bldg 1UP Fountain West #1	10/14/20	7:07	1	DW	G	U	LEAD
	Bldg 1UP Fountain West #2	10/14/20	7:07	1	DW	G	U	LEAD
	Bldg 1UP Staff Bathroom	10/14/20	7:09	1	DW	G	U	LEAD
	Bldg 1UP Room 236	10/14/20	7:11	1	DW	G	U	LEAD

Possible Hazard Identification Hazardous Non-Hazardous Radioactive Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature) *Dave Kendall* Date/Time 10/14/20
 Relinquished By (signature) *Dave Kendall* Date/Time 9:32AM
 Received By (signature) *Dave Kendall* Date/Time 10/14/20 9:34
 Received By (signature) *Dave Kendall* Date/Time