



Microbac Laboratories, Inc., New York Division  
**CERTIFICATE OF ANALYSIS**

J0J1791

**Greene Central School**

**Project Name: Lead Water Testing**

Dave Kendall  
 40 South Canal Street  
 Greene, NY 13778

Project / PO Number: N/A  
 Received: 10/23/2020  
 Reported: 11/18/2020

**Analytical Testing Parameters**

<b>Client Sample ID:</b>	Boy's Coach's Sink	<b>Collected By:</b>	Customer
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	10/20/2020 6:25
<b>Lab Sample ID:</b>	J0J1791-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0069	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1157	LLW

<b>Client Sample ID:</b>	Boy's Side Gym Fountain	<b>Collected By:</b>	Customer
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	10/20/2020 6:25
<b>Lab Sample ID:</b>	J0J1791-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1202	LLW

<b>Client Sample ID:</b>	Kindergarten Hall Fountain	<b>Collected By:</b>	Customer
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	10/20/2020 6:29
<b>Lab Sample ID:</b>	J0J1791-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1204	LLW

<b>Client Sample ID:</b>	Girl's Side Gym Fountain	<b>Collected By:</b>	Customer
<b>Sample Matrix:</b>	Drinking Water	<b>Collection Date:</b>	10/20/2020 6:30
<b>Lab Sample ID:</b>	J0J1791-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0374	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1206	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Girl's Coach's Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:30
<b>Lab Sample ID:</b> J0J1791-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0017	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1208	LLW

<b>Client Sample ID:</b> Room 62 Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:33
<b>Lab Sample ID:</b> J0J1791-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1210	LLW

<b>Client Sample ID:</b> Room 62 BR Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:33
<b>Lab Sample ID:</b> J0J1791-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0034	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1215	LLW

<b>Client Sample ID:</b> Room 61 Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:35
<b>Lab Sample ID:</b> J0J1791-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0265	0.0150 AL	0.0010	mg/L		11/09/20 1328	11/10/20 1227	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Room 61 BR Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:35
<b>Lab Sample ID:</b> J0J1791-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1217	LLW

<b>Client Sample ID:</b> Room 60 Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:37
<b>Lab Sample ID:</b> J0J1791-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0562</b>	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1219	LLW

<b>Client Sample ID:</b> Room 60 BR Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:37
<b>Lab Sample ID:</b> J0J1791-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0027	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1221	LLW

<b>Client Sample ID:</b> Room 59 Sinkn	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:39
<b>Lab Sample ID:</b> J0J1791-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0034	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1222	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Room 59 BR Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:39
<b>Lab Sample ID:</b> J0J1791-13	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1226	LLW

<b>Client Sample ID:</b> Nurse's Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:42
<b>Lab Sample ID:</b> J0J1791-14	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0069	0.0150 AL	0.0051	mg/L	D	11/09/20 1000	11/10/20 1324	LLW

<b>Client Sample ID:</b> Nurse's BR Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:42
<b>Lab Sample ID:</b> J0J1791-15	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0090	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1230	LLW

<b>Client Sample ID:</b> Kitchen Sink Across from DW	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:45
<b>Lab Sample ID:</b> J0J1791-16	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0067	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1231	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Staff Room Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:46
<b>Lab Sample ID:</b> J0J1791-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0148	0.0150 AL	0.0020	mg/L	D	11/09/20 1000	11/10/20 1327	LLW

<b>Client Sample ID:</b> Staff Room BR Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:47
<b>Lab Sample ID:</b> J0J1791-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0015	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1239	LLW

<b>Client Sample ID:</b> Room 27	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:49
<b>Lab Sample ID:</b> J0J1791-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0160</b>	0.0150 AL	0.0020	mg/L	D	11/09/20 1000	11/10/20 1331	LLW

<b>Client Sample ID:</b> Room 29	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:51
<b>Lab Sample ID:</b> J0J1791-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0916</b>	0.0150 AL	0.0010	mg/L		11/09/20 1000	11/09/20 1243	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Room 30	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:52
<b>Lab Sample ID:</b> J0J1791-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0048	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2101	LLW

<b>Client Sample ID:</b> Room 31	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:53
<b>Lab Sample ID:</b> J0J1791-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0032	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2107	LLW

<b>Client Sample ID:</b> Girl's 2nd Grade BR Sink #1	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:55
<b>Lab Sample ID:</b> J0J1791-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2109	LLW

<b>Client Sample ID:</b> Girl's 2nd Grade BR Sink #2	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:55
<b>Lab Sample ID:</b> J0J1791-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2111	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Girl's 2nd Grade BR Sink #3	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:56
<b>Lab Sample ID:</b> J0J1791-25	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2113	LLW

<b>Client Sample ID:</b> Girl's 2nd Grade BR Sink #4	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020
<b>Lab Sample ID:</b> J0J1791-26	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2115	LLW

<b>Client Sample ID:</b> Fountain across from RM 45	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:00
<b>Lab Sample ID:</b> J0J1791-27	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2121	LLW

<b>Client Sample ID:</b> Boy's 2nd Grade BR Sink #1	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:01
<b>Lab Sample ID:</b> J0J1791-28	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2123	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Boy's 2nd Grade BR Sink #2	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:02
<b>Lab Sample ID:</b> J0J1791-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2125	LLW

<b>Client Sample ID:</b> Boy's 2nd Grade BR Sink #3	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:03
<b>Lab Sample ID:</b> J0J1791-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2127	LLW

<b>Client Sample ID:</b> Boy's 2nd Grade BR Sink #4	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:24
<b>Lab Sample ID:</b> J0J1791-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2129	LLW

<b>Client Sample ID:</b> Room 37 Staff BR Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:28
<b>Lab Sample ID:</b> J0J1791-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0017	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2133	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Room 39	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:29
<b>Lab Sample ID:</b> J0J1791-33	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0044	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2135	LLW

<b>Client Sample ID:</b> Room 40	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:31
<b>Lab Sample ID:</b> J0J1791-34	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0402</b>	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2137	LLW

<b>Client Sample ID:</b> Room 41	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:32
<b>Lab Sample ID:</b> J0J1791-35	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0047	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2139	LLW

<b>Client Sample ID:</b> Room 42	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:33
<b>Lab Sample ID:</b> J0J1791-36	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.156</b>	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2145	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Room 43	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:35
<b>Lab Sample ID:</b> J0J1791-37	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0138	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2147	LLW

<b>Client Sample ID:</b> Room 44	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:36
<b>Lab Sample ID:</b> J0J1791-38	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0150	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2149	LLW

<b>Client Sample ID:</b> Room 47	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:38
<b>Lab Sample ID:</b> J0J1791-39	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0014	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2151	LLW

<b>Client Sample ID:</b> Room 48	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:39
<b>Lab Sample ID:</b> J0J1791-40	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1457	11/09/20 2153	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Room 49	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:41
<b>Lab Sample ID:</b> J0J1791-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2203	LLW

<b>Client Sample ID:</b> Main Office BR Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:42
<b>Lab Sample ID:</b> J0J1791-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0018	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2208	LLW

<b>Client Sample ID:</b> Room #3 Conference Rm Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:44
<b>Lab Sample ID:</b> J0J1791-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0020	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2210	LLW

<b>Client Sample ID:</b> Room 4	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:45
<b>Lab Sample ID:</b> J0J1791-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0324	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2212	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Room 5	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:46
<b>Lab Sample ID:</b> J0J1791-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0018	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2214	LLW

<b>Client Sample ID:</b> Room 6	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:47
<b>Lab Sample ID:</b> J0J1791-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0173</b>	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/10/20 1333	LLW

<b>Client Sample ID:</b> Room 7	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:49
<b>Lab Sample ID:</b> J0J1791-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0086	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2222	LLW

<b>Client Sample ID:</b> Room 8	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:51
<b>Lab Sample ID:</b> J0J1791-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0066	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2225	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Room 9	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:52
<b>Lab Sample ID:</b> J0J1791-49	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0037	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2226	LLW

<b>Client Sample ID:</b> Room 10	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:52
<b>Lab Sample ID:</b> J0J1791-50	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0127	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2228	LLW

<b>Client Sample ID:</b> Room 11	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:54
<b>Lab Sample ID:</b> J0J1791-51	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<b>0.0740</b>	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2230	LLW

<b>Client Sample ID:</b> Room 12	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:56
<b>Lab Sample ID:</b> J0J1791-52	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2234	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Room 13	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:57
<b>Lab Sample ID:</b> J0J1791-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0016	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2236	LLW

<b>Client Sample ID:</b> Girl's 1st Grade BR Sink #1	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:58
<b>Lab Sample ID:</b> J0J1791-54	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2238	LLW

<b>Client Sample ID:</b> Girl's 1st Grade BR Sink #2	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:58
<b>Lab Sample ID:</b> J0J1791-55	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2240	LLW

<b>Client Sample ID:</b> Girl's 1st Grade BR Sink #3	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:59
<b>Lab Sample ID:</b> J0J1791-56	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2247	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Girl's 1st Grade BR Sink #4	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:59
<b>Lab Sample ID:</b> J0J1791-57	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2249	LLW

<b>Client Sample ID:</b> Fountain across from Rm 6	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 6:59
<b>Lab Sample ID:</b> J0J1791-58	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2251	LLW

<b>Client Sample ID:</b> Boy's 1st Grade BR Sink #1	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:00
<b>Lab Sample ID:</b> J0J1791-59	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2253	LLW

<b>Client Sample ID:</b> Boy's 1st Grade BR Sink #2	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:00
<b>Lab Sample ID:</b> J0J1791-60	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/09/20 1459	11/09/20 2255	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

<b>Client Sample ID:</b> Boy's 1st Grade BR Sink #3	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:00
<b>Lab Sample ID:</b> J0J1791-61	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/10/20 1231	11/10/20 1556	LLW

<b>Client Sample ID:</b> Boy's 1st Grade BR Sink #4	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:00
<b>Lab Sample ID:</b> J0J1791-62	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	<0.0010	0.0150 AL	0.0010	mg/L		11/10/20 1231	11/10/20 1602	LLW

<b>Client Sample ID:</b> 1st Grade Staff BR Sink	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:01
<b>Lab Sample ID:</b> J0J1791-63	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0010	0.0150 AL	0.0010	mg/L		11/10/20 1231	11/10/20 1604	LLW

<b>Client Sample ID:</b> Room 21	<b>Collected By:</b> Customer
<b>Sample Matrix:</b> Drinking Water	<b>Collection Date:</b> 10/20/2020 7:02
<b>Lab Sample ID:</b> J0J1791-64	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
<b>Method: EPA 200.8, Rv. 5.4 (1994)</b>								
Lead	0.0382	0.0150 AL	0.0010	mg/L		11/10/20 1231	11/10/20 1606	LLW





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1791

Client Sample ID: Room 22	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/20/2020 7:05
Lab Sample ID: J0J1791-65	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0060	0.0150 AL	0.0010	mg/L		11/10/20 1231	11/10/20 1607	LLW

Client Sample ID: Room 23	Collected By: Customer
Sample Matrix: Drinking Water	Collection Date: 10/20/2020 7:06
Lab Sample ID: J0J1791-66	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.0150 AL	0.0010	mg/L		11/10/20 1231	11/10/20 1609	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Jennifer Walker  
 Operations Manager  
 Reported: 11/18/2020 10:42

**CHAIN OF CUSTODY RECORD**

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on ice?  Yes  No  N/A

Custody Seals Intact?  Yes  No  N/A

Level 2  Level 3  Level 4  EDD

Compliance Monitoring?  Yes  No

Agency/Program

Invoice Address

Client Name: Greene Central School District

Address: 40 South Canal St

City, State, Zip: Greene, NY, 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report Via:  Mail  Fax  e-mail (address)

Send Invoice Via:  Mail  Fax  e-mail (address)

Location: Primary School

PO No.:

Sampler Phone No.: (607) 240-3966

Sampler Signature: *Brandon Simonds*

Sampler Signature: *Brandon Simonds*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)  
 \*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

**REQUESTED ANALYSIS**

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **
	Boy's Coach's Sink	10/20/20	6:25	1	DW	G	U LEAD
	Boy's side gym Fountain	10/20/20	6:25	1	DW	G	U LEAD
	Kindergarten Hall Fountain	10/20/20	6:29	1	DW	G	U LEAD
	Girl's side gym Fountain	10/20/20	6:30	1	DW	G	U LEAD
	Girl's Coach's Sink	10/20/20	6:30	1	DW	G	U LEAD
	Room 62 Sink	10/20/20	6:33	1	DW	G	U LEAD
	Room 62 BR Sink	10/20/20	6:33	1	DW	G	U LEAD
	Room 61 Sink	10/20/20	6:35	1	DW	G	U LEAD
	Room 61 BR Sink	10/20/20	6:35	1	DW	G	U LEAD
	Room 60 Sink	10/20/20	6:37	1	DW	G	U LEAD

Possible Hazard Identification  Hazardous  Non-Hazardous  Radioactive

Sample Disposition  Dispose as appropriate  Return  Archive

Comments

Please email to DKendall@GreeneCSD.ORG

Relinquished By (signature) *Dave Kendall*

Date/Time 10/23/20

8:49 AM

Received By (signature) *AK*

Date/Time 10/23/2008



Greene Central School  
PM: Shannon Weeks

Additional A

**CHAIN OF CUSTODY RECORD**

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice?  Yes  No  N/A

Custody Seals Intact?  Yes  No  N/A

Level 1  Level 2  Level 3  Level 4  EDD

Send Invoice via:  Mail  Fax  e-mail (address)

Compliance Monitoring?  Yes  No

Agency/Program

Sampler Phone No.: (607) 240-3966

Sampler Signature: *Brenda Simonds*

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

**REQUESTED ANALYSIS**

Turnaround Time

Routine (5 to 7 business days)

RUSH\* (notify lab)

Report Type

Results Only  Mail  Fax  e-mail (address)

Level 1  Level 2  Level 3  Level 4  EDD

Send Invoice via:  Mail  Fax  e-mail (address)

Compliance Monitoring?  Yes  No

Agency/Program

Sampler Phone No.: (607) 240-3966

Sampler Signature: *Brenda Simonds*

Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Invoice Address

Client Name: Greene Central School District

Address: 40 South Canal St

City, State, Zip: Greene, NY, 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via:  Mail  Fax  e-mail (address)

Project: Primary School

Location: Primary School

PO No.:

Sampled by (PRINT): *Brenda Simonds*

Sampler Signature: *Brenda Simonds*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	Room 60 BR Sink	10/20/20	6:37	1	DW	G	U	LEAD
	Room 59 Sink	10/20/20	6:37	1	DW	G	U	LEAD
	Room 59 BR Sink	10/20/20	6:39	1	DW	G	U	LEAD
	Nurse's Sink	10/20/20	6:42	1	DW	G	U	LEAD
	Nurse's BR Sink	10/20/20	6:43	1	DW	G	U	LEAD
	Kitchen Sink Across from DW	10/20/20	6:45	1	DW	G	U	LEAD
	Staff Room Sink	10/20/20	6:46	1	DW	G	U	LEAD
	Staff Room BR Sink	10/20/20	6:47	1	DW	G	U	LEAD
	Room 27	10/20/20	6:49	1	DW	G	U	LEAD
	Room 29	10/20/20	6:51	1	DW	G	U	LEAD

Possible Hazard Identification  Hazardous  Non-Hazardous  Radioactive

Sample Disposition  Dispose as appropriate  Return  Archive

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Please email to DKendall@GreeneCSD.ORG

*10/28/20 8:44 AM*

*Dave Kendall*

*10/28/20 8:44 AM*

*Dave Kendall*

*10/28/20 8:44 AM*

**CHAIN OF CUSTODY RECORD**

Number  
Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time

Routine (5 to 7 business days)  
 RUSH\* (notify lab)

Temperature Upon Receipt (°C)  
Therm ID

Holding Time

Samples Received on Ice?  Yes  No  N/A

Custody Seals Intact?  Yes  No  N/A

Invoice Address

Client Name: Greene Central School District

Address: 40 South Canal St

City, State, Zip: Greene, NY, 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via:  Mail  Fax  e-mail (address)

Send Invoice via:  Mail  Fax  e-mail (address)

Project: Primary School

Location: Primary School

PO No.:

Compliance Monitoring?  Yes  No  
 Agency/Program

Sampled by (PRINT): *Brandon Swinick*

Sampler Signature: *Brandon Swinick*

Sampler Phone No.: (607) 240-3966

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)  
\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

**REQUESTED ANALYSIS**

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grb / Comp	Preservative Types **	Additional Notes
	Room 30	10/20/20	6:53	1	DW	G	U	LEAD
	Room 31	10/20/20	6:53	1	DW	G	U	LEAD
	Girl's 2nd Grade BR Sink #1	10/20/20	6:55	1	DW	G	U	LEAD
	Girl's 2nd Grade BR Sink #2	10/20/20	6:55	1	DW	G	U	LEAD
	Girl's 2nd Grade BR Sink #3	10/20/20	6:56	1	DW	G	U	LEAD
	Girl's 2nd Grade BR sink #4	10/20/20	6:57	1	DW	G	U	LEAD
	Fountain across from RM 45	10/20/20	7:00	1	DW	G	U	LEAD
	Boy's 2nd Grade BR Sink #1	10/20/20	7:01	1	DW	G	U	LEAD
	Boy's 2nd Grade BR Sink #2	10/20/20	7:02	1	DW	G	U	LEAD
	Boy's 2nd Grade BR Sink #3	10/20/20	7:03	1	DW	G	U	LEAD

Possible Hazard Identification  Hazardous  Non-Hazardous  Radioactive  Sample Disposition  Dispose as appropriate  Return  Archive

Comments  
Please email to DKendall@GreeneCSD.ORG

Relinquished By (signature) *Dave Kendall* Date/Time 10/20/20 8:44 AM  
Received By (signature) \_\_\_\_\_ Date/Time \_\_\_\_\_

Relinquished By (signature) \_\_\_\_\_ Date/Time \_\_\_\_\_  
Received By (signature) \_\_\_\_\_ Date/Time \_\_\_\_\_

Relinquished By (signature) \_\_\_\_\_ Date/Time \_\_\_\_\_  
Received By (signature) \_\_\_\_\_ Date/Time \_\_\_\_\_

**CHAIN OF CUSTODY RECORD**

**MICROBAC\*** 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Temperature Upon Receipt (°C)

Therm ID

Holding Time

Samples Received on Ice?  Yes  No  N/A

Custody Seals Intact?  Yes  No  N/A

Level 1  Level 2  Level 3  Level 4  EDD

Compliance Monitoring?  Yes  No

Agency/Program

Report Type

Results Only  Mail  Fax  e-mail (address)

Sampler Phone No.: (607) 240-3966

Client Name: Greene Central School District

Address: 40 South Canal St

City, State, Zip: Greene, NY, 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via:  Mail  Fax  e-mail (address)

Location: Primary School

PO No.:

Sampler Signature: *[Signature]*

Sampler Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)

Matrix Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Requested Analysis

Lab ID

Client Sample ID

Date Collected

Time Collected

No. of Containers

Matrix

Preservative Types \*\*

Sample Disposition

Received By (signature)

Additional Notes

Received By (signature)

Received By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

Relinquished By (signature)

**CHAIN OF CUSTODY RECORD**  
Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time

Routine (5 to 7 business days)  
 RUSH\* (notify lab)

Temperature Upon Receipt (°C)  
Therm ID

Holding Time

Samples Received on Ice?  Yes  No  N/A

Custody Seals Intact?  Yes  No  N/A

Level 1  Level 2  Level 3  Level 4  EDD

Invoice Address

Client Name: Greene Central School District

Address: 40 South Canal St

City, State, Zip: Greene, NY, 13778

Contact: Dave Kendall

Telephone No.: (607) 240-3966

Send Report via:  Mail  Fax  e-mail (address)

Send Invoice via:  Mail  Fax  e-mail (address)

Project: Primary School

Location: Primary School

PO No.:

Compliance Monitoring?  Yes  No  
 Agency/Program

Sampled by (PRINT): *Nick Stanino*

Sampler Signature: *[Signature]*

Sampler Phone No.: (607) 240-3966

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)  
\*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

**REQUESTED ANALYSIS**

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Additional Notes
	Room 48	10/20/20		1	DW	G	U	LEAD
	Room 49	10/20/20	6:41	1	DW	G	U	LEAD
	Main Office BR Sink	10/20/20	6:42	1	DW	G	U	LEAD
	Room #3 Conference Rm Sink	10/20/20	6:44	1	DW	G	U	LEAD
	Room 4	10/20/20	6:45	1	DW	G	U	LEAD
	Room 5	10/20/20	6:46	1	DW	G	U	LEAD
	Room 6	10/20/20	6:47	1	DW	G	U	LEAD
	Room 7	10/20/20	6:49	1	DW	G	U	LEAD
	Room 8	10/20/20	6:51	1	DW	G	U	LEAD
	Room 9	10/20/20	6:52	1	DW	G	U	LEAD

Possible Hazard Identification  Hazardous  Non-Hazardous  Radioactive

Sample Disposition  Dispose as appropriate  Return  Archive

Relinquished By (Signature) *[Signature]*

Date/Time 10/20/20

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Please email to DKendall@GreeneCSD.ORG

**CHAIN OF CUSTODY RECORD**

Number *Instructions on back*  
 TO BE COMPLETED BY MICROBAC

**Lab Report Address**  
 Client Name: Greene Central School District  
 Address: 40 South Canal St  
 City, State, Zip: Greene, NY, 13778  
 Contact: Dave Kendall  
 Telephone No.: (607) 240-3966

**Invoice Address**  
 Client Name: Greene Central School District  
 Address: 40 South Canal St  
 City, State, Zip: Greene, NY, 13778  
 Contact: Dave Kendall  
 Telephone No.: (607) 240-3966

**Turnaround Time**  
 Routine (5 to 7 business days)  
 RUSH\* (notify lab)

**Temperature Upon Receipt (°C)**  
 Therm ID \_\_\_\_\_  
 Holding Time \_\_\_\_\_

**Results**  
 Level 1  Level 2  Level 3  Level 4  EDD

**Send Report via:**  Mail  Fax  e-mail (address)

**Send Invoice via:**  Mail  Fax  e-mail (address)

**Project:** Primary School  
**Location:** Primary School  
**PO No.:** \_\_\_\_\_

**Compliance Monitoring?**  Yes  No  
 Agency/Program

**Sampler Signature:** *Nick Straniero*  
**Sampler Phone No.:** (607) 240-3966

**Sampled by (PRINT):** *Nick Straniero*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (WW), Other (specify)  
 \*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grat / Comp	Preservative Types **	Sample Disposition	Requested Analysis	Additional Notes
	Room 10	10/20/20	6:52	1	DW	G	U	<input checked="" type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive		
	Room 11	10/20/20	6:54	1	DW	G	U			
	Room 12	10/20/20	6:56	1	DW	G	U			
	Room 13	10/20/20	6:57	1	DW	G	U			
	Girl's 1st Grade BR Sink #1	10/20/20	6:58	1	DW	G	U			
	Girl's 1st Grade BR Sink #2	10/20/20	6:58	1	DW	G	U			
	Girl's 1st Grade BR Sink #3	10/20/20	6:59	1	DW	G	U			
	Girl's 1st Grade BR Sink #4	10/20/20	6:59	1	DW	G	U			
	Fountain across from Rm 6	10/20/20	6:59	1	DW	G	U			
	Boy's 1st Grade BR Sink #1	10/20/20	7:00	1	DW	G	U			

**Possible Hazard Identification**  
 Hazardous  Non-Hazardous  Radioactive

**Comments**  
 Please email to DKendall@GreeneCSD.ORG

**Relinquished By (signature)** *Dave Kendall* **Date/Time** 10/20/20 8:44 AM  
**Relinquished By (signature)** \_\_\_\_\_ **Date/Time** \_\_\_\_\_  
**Relinquished By (signature)** \_\_\_\_\_ **Date/Time** \_\_\_\_\_

**CHAIN OF CUSTODY RECORD**

MICROBAC® 3821 Buck Dr., Cortland, NY 13045 | 607.753.3403 p | 607.753.3415 f

Number

Instructions on back

TO BE COMPLETED BY MICROBAC

Turnaround Time

Temperature Upon Receipt (°C)

Routine (5 to 7 business days)

Therm ID

RUSH\* (notify lab)

Holding Time

(needed by)

Samples Received on Ice?  Yes  No  N/A

Custody Seals Intact?  Yes  No  N/A

Level 1  Level 2  Level 3  Level 4  EDD

Send Invoice via:  Mail  Fax  e-mail (address)

Compliance Monitoring?  Yes  No

Agency/Program

Sampler Phone No.: (607) 240-3966

Sampler Signature: *[Signature]*

\* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)  
 \*\* Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

**REQUESTED ANALYSIS**

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Sample Disposition	Date/Time	Additional Notes
	Boy's 1st Grade BR Sink #2	10/20/20	7:20	1	DW	G	U	<input type="checkbox"/> Dispose as appropriate <input type="checkbox"/> Return <input type="checkbox"/> Archive	10/23/20 8:51	
	Boy's 1st Grade BR Sink #3	10/20/20	7:20	1	DW	G	U			
	Boy's 1st Grade BR Sink #4	10/20/20	7:20	1	DW	G	U			
	1st Grade Staff BR Sink	10/20/20	7:01	1	DW	G	U			
	Room 21	10/20/20	7:02	1	DW	G	U			
	Room 22	10/20/20	7:05	1	DW	G	U			
	Room 23	10/20/20	7:06	1	DW	G	U			

Possible Hazard Identification  Hazardous  Non-Hazardous  Radioactive

Comments

Please email to DKendall@GreeneCSD.ORG

Relinquished By (signature) *[Signature]*

Date/Time 10/23/20

8:54 AM

Received By (signature) *[Signature]*

Date/Time 10/23/20 8:51

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time

Relinquished By (signature)

Date/Time

Received By (signature)

Date/Time